

Job Name:

Schedule Reference:

Date:



MODULAR WATER-SOURCE VRF HEAT PUMP

Standard Installation (*1) PQHY-P240ZSLMU-A1
 Geothermal Installation (*1)(*2) PQHY-P240ZSLMU-A1

ACCESSORIES

- Twinning Kit * CMY-Y100GBK3
Twinning Kit is necessary to combine the refrigerant flow of the modules and is sold separately.
- T-Branch Joint (≤ 72,000 Btu/h) CMY-Y102SS-G2
- T-Branch Joint (73,000 - 144,000 Btu/h) CMY-Y102LS-G2
- T-Branch Joint (145,000 - 234,000 Btu/h) CMY-Y202S-G2
- T-Branch Joint (≥ 235,000 Btu/h) CMY-Y302S-G2
- Header - 4 Branch (Capacity: ≤ 72,000 Btu/h) CMY-Y104C-G
- Header - 8 Branch (Capacity: ≤ 144,000 Btu/h) CMY-Y108C-G
- Header - 10 Branch (Capacity: ≤ 234,000 Btu/h) CMY-Y1010C-G

Specifications		System	Module 1	Module 2
Unit Type		PQHY-P240ZSLMU-A1	PQHY-P120ZLMU-A1	PQHY-P120ZLMU-A1
Nominal Cooling Capacity (575V) (*1)	Btu/h	240,000	120,000	120,000
Nominal Heating Capacity (575V) (*1)(*2)	Btu/h	270,000	135,000	135,000
Operating Temperature Range	Cooling (Indoor)	Refer to Module Data	59~75° F (15~24° C) WB	
	Heating (Indoor)		59~81° F (15~27° C) DB	
Operating Water Temperature Range	Cooling (*3)	Refer to Module Data	50~113° F (10~45° C)	
	Heating (*3)		50~113° F (10~45° C)	
External Dimensions (H x W x D)	In. (mm)	Refer to Module Data	43-5/16 x 34-11/16 x 21-11/16 (1100 x 880 x 550)	43-5/16 x 34-11/16 x 21-11/16 (1100 x 880 x 550)
Net Weight	Lbs. (kg)	826 (374)	413 (187)	413 (187)
External Finish		Refer to Module Data	Galvanized steel sheet	
Electrical Power Requirements	Voltage, Phase, Hertz	Refer to Module Data (*4)	575V, 3-phase, 60Hz	
Minimum Circuit Ampacity (MCA) (*4) (*)	A	Refer to Module Data (*4)	11	11
Maximum Overcurrent Protection (MOP) (*4)	A	Refer to Module Data (*4)	15	15
<i>Circulating Water (quality must meet regulations)</i>				
Flow Rate	GPM	Refer to Module Data	25.4	25.4
Pressure Drop	psi		3.48	3.48
Operation Volume Range	GPM		13.2 - 31.7	13.2 - 31.7
Maximum Water Pressure	psi		290	290
Water-source Connection for Inlet and Outlet	In.		NPT1-1/2 Screw (Install strainer (more than 50 meshes) at water inlet piping of the unit)	
<i>Piping Diameter (Brazed)</i>				
From Twinning Kit to First Joint or Header (In. / mm)	Liquid (High Pressure)	5/8 / 15.88	Refer to System Data	Refer to System Data
	Gas (Low Pressure)	1-1/8 / 28.58	Refer to System Data	Refer to System Data
From Modules to Twinning Kit (In. / mm)	Liquid (High Pressure)	Refer to Module Data	1/2 / 12.7	1/2 / 12.7
	Gas (Low Pressure)	Refer to Module Data	7/8 / 22.2	7/8 / 22.2
Max. Total Refrigerant Line Length	Ft.	2,460	Refer to System Data	Refer to System Data
Max. Refrigerant Line Length (Bet. ODU & IDU)	Ft.	541		
Max. Control Wiring Length	Ft.	1,640		
Indoor Unit	Total Capacity	50~130%	Refer to System Data	Refer to System Data
	Model / Quantity	P06~P96 / 2~50	Refer to System Data	Refer to System Data
Sound Pressure Level	dB(A)	57	54	54
Compressor Operating Range		7% - 100%	Refer to System Data	Refer to System Data
Compressor Type x Quantity		Refer to Module Data (*4)	Inverter scroll hermetic compressor x 1	Inverter scroll hermetic compressor x 1
Refrigerant		Refer to Module Data	R410A x 11 lbs. + 1 oz. (5.0 kg)	R410A x 11 lbs. + 1 oz. (5.0 kg)
Protection Devices	High Pressure	Refer to Module Data	High pressure sensor, High pressure switch at 4.15 MPa (601 psi)	High pressure sensor, High pressure switch at 4.15 MPa (601 psi)
	Inverter Circuit		Over-heat protection, Over-current protection	Over-heat protection, Over-current protection
	Compressor		Over-heat protection	Over-heat protection
AHRI Ratings (Ducted/Non-Ducted)	EER	12.5 / 13.9	Refer to System Data	
	IEER	22.4 / 25.7	Refer to System Data	
	COP	5.49 / 5.35	Refer to System Data	

Should this document be altered or changed without MESCA's permission, it becomes null and void. MESCA assumes no responsibility for any consequences in such cases.

NOTES: (*1) <CITY MULTI indoor unit>
 Nominal cooling conditions (Test conditions are based on AHRI 1230)
 Indoor: 81°F D.B./68°F W.B. (27°C D.B./19°C W.B.),
 Water temperature: 86°F (30°C)
 Brine concentration: 0%

Nominal heating conditions (Test conditions are based on AHRI 1230)
 Indoor: 68°F D.B. (20°C D.B.),
 Water temperature: 68°F (20°C)
 Brine concentration: 0%

(*2) <PWFY-P36/72NMU-E-AU>
 Nominal cooling conditions
 Circulating water Temp.: 86 °F (30 °C)
 Pipe length : 25 ft. (7.6 m)
 Level difference : 0 ft. (0 m)
 Inlet water Temp. : 149 °F (23 °C)
 Water flow rate : 1.93 m³/h (8.3 gpm) <P36> / 3.86 m³/h (16.6 gpm) <P72>
 Brine concentration : 0 %

Nominal heating conditions
 Circulating water Temp. : 68 °F (20 °C)
 Pipe length : 25 ft. (7.6 m)
 Level difference : 0 ft. (0 m)
 Inlet water Temp. : 86 °F (30 °C)
 Water flow rate : 2.15 m³/h (9.2 gpm) <P36> / 4.30 m³/h (18.5 gpm) <P72>
 Brine concentration : 0 %

(*3) If using circulating water temperatures between 23° and 50° F, Dip switch 3-9 must be turned on and glycol (antifreeze) must be added to the water loop to prevent freezing down to 5° F.

(*4) <Each individual module requires a separate electrical connection.>


Note: Mitsubishi Electric (MESCA) supports the use of only MESCA supplied and approved accessories for proper functioning of the unit(s). Use of non-MESCA supported accessories will affect warranty coverage.

* All electrical work shall comply with National (CEC) and local codes and regulations.

Should this document be altered or changed without MESCA's permission, it becomes null and void. MESCA assumes no responsibility for any consequences in such cases.

Module: PQHY-P240ZSLMU-A1 - DIMENSIONS

Unit: mm(in)



- Note 1. Connect the pipes as shown in the figure above. Refer to the table below for the pipe size.
 2. Twinning pipe should not be tilted more than 15 degrees from the horizontal plane.
 3. See the Installation Manual for the details of Twinning pipe installation.
 4. The pipe section before the Twinning pipe (sections "a" and "b" in the figure) must have at least 500mm (19-11/16) of straight section (*including the straight pipe that is supplied with the Twinning pipe).
 5. Only use the Twinning pipe by Mitsubishi (optional parts).

Twinning pipe connection size

Package unit name	PQHY-P144ZSLMU-A1	PQHY-P168ZSLMU-A1	PQHY-P192ZSLMU-A1	PQHY-P216ZSLMU-A1	PQHY-P240ZSLMU-A1
Heat Source unit 1	PQHY-P72ZLUMU-A1	PQHY-P96ZLUMU-A1	PQHY-P120ZLUMU-A1	PQHY-P144ZLUMU-A1	PQHY-P168ZLUMU-A1
Heat Source unit 2	PQHY-P72ZLUMU-A1	PQHY-P96ZLUMU-A1	PQHY-P120ZLUMU-A1	PQHY-P144ZLUMU-A1	PQHY-P168ZLUMU-A1
Twinning pipe Kit(optional parts)	CMT-Y100CBK3				
Indoor unit~ Twinning pipe	ø12.7(1/2)	ø15.88(5/8)			
		ø28.58(1-1/8)			
Twinning pipe-Heat Source unit 1		ø9.52(3/8)	ø12.7(1/2)		
Twinning pipe-Heat Source unit 2		ø19.05(3/4)	ø22.2(7/8)	ø12.7(1/2)	
		ø9.52(3/8)	ø22.2(7/8)	ø12.7(1/2)	
		ø19.05(3/4)	ø22.2(7/8)	ø12.7(1/2)	


Specifications are subject to change without notice.

Modules: 1, 2 : PQHY-P120ZLMU-A1 - DIMENSIONS

Unit: mm(in)

- <Accessories>
- Refrigerant (Liquid) conn. pipe..... 1pc.
(P72/P96/P120 ; Packaged in the accessory kit)
 - Refrigerant (Gas) conn. elbow..... 1pc.
(P72/P96/P120 ; Packaged in the accessory kit)
 - Water stopper(Liquid Gas)..... 1pc. each
(P72/P96/P120 ; Packaged in the accessory kit)
 - Sealing material for water stopper (Liquid Gas)..... 1pc. each
(P72/P96/P120 ; Packaged in the accessory kit)
 - Sealing material for field piping (Liquid Gas)..... 1pc. each
(P72/P96/P120 ; Packaged in the accessory kit)
 - Sealing material for drain socket..... 1pc.
(P72/P96/P120 ; Packaged in the accessory kit)
 - Pipe cover for gas..... 1pc.
(P72/P96/P120 ; Packaged in the accessory kit)

- Note1. Close a hole of the water piping, the refrigerant piping, the power supply, and the control wiring and unused knockout holes with the putty etc. so as not to infiltrate rain water etc.(field erection work)
- Note2. At the time of product shipment, the front side piping specification serves as the local drainage connection. When connecting on the rear side, please remove the rear side plug sealing corks, and attach a front side.
- Note3. Ensure there is no leak after the attachment has been fitted. Take notice of service space as Fig.A. (In case of single installation, 600mm(23-5/8) or more of back space as front space makes easier access when servicing the unit from rear side.)
- Note4. If water pipes or refrigerant pipes stretch upward, required space for service and maintenance due to replacement of control box is shown in Fig.B.
- Note5. Environmental condition for installation; -20~40°C(DB)(-4~104°F) as indoor installation.
- Note6. In case the temperature around the heat source unit has possibility to drop under 0°C(32°F), be careful for the following point to prevent the pipe burst by the water pipe freeze-up.
- Circulate the water all the time even if the heat source unit is not in operation.
 - Drain the water from inside of the heat source unit when the heat source unit will not operate for a long term.
- Note7. Ensure that the drain piping is downward with a pitch of more than 1/100.
- Note8. At brazing of pipes, wrap the refrigerant service valve with wet cloth and keep the temperature of refrigerant service valve under 120°C(248°F).



NO.	Usage	Specifications
①	For pipes	140×77 Knockout hole (5-9/16) (3-1/16)
②	For wires	φ62.7 or φ34.5 Knockout hole (2-1/2) (1-3/8)
③	For transmission cables	φ43.7 or φ22.2 Knockout hole (1-3/4) (7/8)
④	Water pipe inlet	φ34 Knockout hole (1-3/8)
⑤	Water pipe outlet	NPT1-1/2 Screw
⑦	Drain pipe	NPT1-1/2 Screw Rc3/4 Screw




Fig. A

Fig. B


Connecting pipe specifications

Model	Refrigerant pipe		Service valve	
	Liquid	Gas	Liquid	Gas
PQHY-P120ZLMU-A1	φ9.52 Braze (3/8) *1 *4	φ19.05 Braze (3/4) *1 *4	φ9.52 (3/8)	φ25.4 (1)
PQHY-P96ZLMU-A1	φ9.52 Braze (3/8) *1	φ17.1 Braze (1/2) *2 *4	φ9.52 (3/8)	φ25.4 (1)
PQHY-P72ZLMU-A1	φ9.52 Braze (3/8) *1	φ12.7 Braze (1/2) *3 *4	φ9.52 (3/8)	φ25.4 (1)

- *1. Connect by using the connecting pipes and elbow that are supplied.
- *2. Total length is 30m (295ft)
- *3. Total length is 40m (131ft)
- *4. Use the pipe joint (field supply) and connect to the refrigerant service valve piping.


CMY-Y100CBK3

For Gas pipe:




ID: Inner Diameter OD: Outer Diameter

For Liquid pipe:




<Reducer(Accessory)>



in.

Note 1. Reference the attitude angle of the branch pipe below the fig.




The angle of the branch pipe for high pressure is within $\pm 15^\circ$ against the horizontal plane.

2. Use the attached pipe to braze the port-opening of the distribute
3. Pipe diameter is indicated by inside diamete
4. Only use the Twinning pipe by Mitsubishi (optional parts)

Should this document be altered or changed without MESCA's permission, it becomes null and void. MESCA assumes no responsibility for any consequences in such cases.

Notes:



for a greener tomorrow

